



1 LEVEL 5 - POWER - SECTOR C1  
1/4" = 1'-0"

KEYNOTES	
1	PROVIDE CIRCUITS AS SHOWN FOR POWER FEED TO MODULAR FURNITURE SYSTEM. COORDINATE EXACT ROUGH-IN LOCATION PRIOR TO INSTALLATION.
2	COORDINATE ROUGH-IN DETAILS OF ELECTRICAL OUTLET INSTALLED IN BENCH.
3	PROVIDE 120V/15A POWER TO RESISTIVE DAMPER. MAKE REQUIRED CONNECTION TO THE FIRE ALARM SYSTEM. PROVIDE RELAY AND INTERFACE MODULE AS REQUIRED. DAMPER IS POWERED OPEN AND SPRING CLOSED. COORDINATE WITH MECHANICAL CONTRACTOR PRIOR TO ROUGH-IN.

**TLC ENGINEERING SOLUTIONS**  
201 St. Charles Avenue  
Suite 4318  
New Orleans, LA 70170  
P 504.777.0945  
TLC No. 721067  
www.tlc-engineers.com  
EF 5319  
www.ef-engineers.com  
THINK. LISTEN. CREATE.

**multistudio**  
the evolution of gould evans  
+  
**PERKINS — EASTMAN**

**LSU-HSC MEB  
LABORATORY  
RENOVATION**  
1901 PERDIDO STREET  
NEW ORLEANS, LA 70112

Project Number: 1321-1100  
Owner: State of Louisiana - Facility Planning and Control  
1302 N. Third St., Suite 7-210  
Baton Rouge, LA 70802  
225.342.7000  
www.dhs.la.gov/foia/psc/  
architects: Multistudio  
3308 Magazine Street  
New Orleans, LA 70115  
504.681.6303  
www.multistudio.com  
Perkins Eastman  
115 5th Ave.  
New York, NY 10003  
212.353.7200  
www.perkinseastman.com  
structural engineer: Schreier, Endom & Flanagan Consulting Engineers  
4227 Bienville Avenue  
New Orleans, LA 70113  
504.482.7856  
www.se-engineers.com  
MEP/FP + technology engineer: TLC Engineering Solutions  
201 St. Charles Ave., Suite 4318  
New Orleans, LA 70170  
504.777.0945  
www.tlc-engineers.com

Issue Date:		01/12/2024
Revisions		
NUMBER	DESCRIPTION	DATE
1	ADD 011	01/10/2025

UNLESS A PROFESSIONAL SEAL WITH SIGNATURE AND DATE IS AFFIXED, THIS DOCUMENT IS PRELIMINARY AND IS NOT INTENDED FOR CONSTRUCTION, RECORDING PURPOSES OR IMPLEMENTATION.

**POWER & FIRE ALARM  
PLAN - LEVEL 5 -  
SECTOR C1  
E205-C1**  
CONSTRUCTION  
DOCUMENTS