

KEYNOTES

1

PROVIDE CIRCUITS AS SHOWN FOR POWER FEED TO MODULAR FURNITURE SYSTEM. COORDINATE EXACT ROUGH-IN LOCATION PRIOR TO INSTALLATION.

2

COORDINATE ROUGH-IN DETAILS OF ELECTRICAL OUTLET INSTALLED IN BENCH MILLWORK PRIOR TO INSTALL.

TLC ENGINEERING SOLUTIONS

201 St. Charles Avenue
Suite 437B
New Orleans, LA 70170
P 504.777.0945
F 504.777.0945
www.tlc-engineers.com
TLC No. 721067

201 St. Charles Avenue
Suite 437B
New Orleans, LA 70170
P 504.777.0945
F 504.777.0945
www.tlc-engineers.com
TLC No. 721067

THINK. LISTEN. CREATE.

multistudio

the evolution of gould evans

+

PERKINS — EASTMAN

LSU-HSC MEB
LABORATORY
RENOVATION

1901 PERDODO STREET
NEW ORLEANS, LA 70112

Project Number: 1921-100

State of Louisiana - Facility Planning and Control
1205 N. Third St., Suite 7120
Baton Rouge, LA 70802
225.342.7000
www.doc.state.la.gov/itna/tnc/

Architects:
Multistudio
3305A Magazine Street
New Orleans, LA 70115
504.581.1500
www.multistudio.com

Perkins Eastman
115 39th Ave
New York, NY 10003
212.933.7300
www.perkinseastman.com

Structural Engineer:
Schwenk, Endom & Flanagan Consulting Engineers,
4227 Bienville Avenue
New Orleans, LA 70115
504.587.7006
www.safengineers.com

ME/FP - Technology Engineer:
TLC Engineering Solutions
201 St. Charles Ave., Suite 437B
New Orleans, LA 70170
504.777.0945
www.tlc-engineers.com

FOR REFERENCE
ONLY

1 LEVEL 5 - POWER - SECTOR C3


1/4" = 1'-0"

Issue Date: 01/12/2024

Revisions

| NUMBER | DESCRIPTION | DATE |
|--------|-------------|------|
|--------|-------------|------|

UNLESS A PROFESSIONAL SEAL WITH SIGNATURE AND DATE IS
AFFIXED, THIS DOCUMENT IS PRELIMINARY AND IS NOT INTENDED FOR
CONSTRUCTION, RECORDING PURPOSES OR IMPLEMENTATION



POWER & FIRE ALARM
PLAN - LEVEL 5 -
SECTOR C3

E205-C3

CONSTRUCTION
DOCUMENTS