TLC ENGINEERING SOLUTIONS
201 St. Charles Avenue
Suite 4318
New Orleans, LA 70170
P 504.777.0040
EF 3319
www.tlc-engineers.com
TLC No.:721097
THINK. LISTEN. CREATE.
©Copyright 2023

multistudio
the evolution of gould evans
+
PERKINS EASTMAN

LSU-HSC MEB LABORATORY RENOVATION

1901 PERDIDO STREET
NEW ORLEANS, LA 70112

Project Number: 1321-1100

owner:
State of Louisiana - Facility Planning and Control
1203 N. Third St., Suite 7-210
Baton Rouge, LA 70802
225.342.7000
www.doa.la.gov/doa/fpc/

architects:
Multistudio
330BA Magazine Street
New Orleans, LA 70115
504.681.6303
www.multi.studio

Perkins Eastman
115 5th Ave
New York, NY 10003
212.353.7200
www.perkinseastman.com

structural engineer:
Schrenk, Endom & Flanagan Consulting Engineers,
4227 Bienville Avenue
New Orleans, LA 70119
504.482.7856
www.sefengineers.com

MEP/FP + technology engineer:
TLC Engineering Solutions
201 St. Charles Ave, Suite 4318
New Orleans, LA 70170
504.777.0040
www.tlc-engineers.com

KEYED NOTES ⬡ :

1. EXISTING ELECTRONIC SECURITY DEVICES AND CARD READER TO REMAIN ON THIS DOOR.
2. PROVIDE JUNCTION BOX IN ACCESSIBLE CEILING ABOVE DOOR FOR CONDUITS TO ELECTRONIC SECURITY DEVICES. PROVIDE 3/4" CONDUITS FROM JUNCITON BOX TO DOOR FRAME/ELECTRONIC LOCKING DEVICE. DOOR POSITION SWITCH, AND CARD READER. PROVIDE 4"X4" ELECTRICAL BOX. 2.5" DEEP WITH SINGLE GANG MUD RING FOR READER.
3. REFER TO SECURITY DOOR DETAILS FOR MORE INFORMATION ON ROUGH-IN REQUIREMENTS FOR DOOR TYPE C3 AND C4 DOORS. TYPICAL OF ALL.

HORIZONTAL DISTRIBUTION NOTES ◇ :

1. TERMINATE STRUCTURED TELECOMMUNICATIONS DATA CABLING IN THIS AREA ON PATCH PANELS INSTALLED ON RACKS IN IT ROOM 5321, UNLESS NOTED OTHERWISE.
2. TERMINATE SECURITY SYSTEM CABLING IN THIS AREA AT SECURITY EQUIPMENT INSTALLED IN IT ROOM 5321, UNLESS NOTED OTHERWISE.

SECURITY CAMERAS - LEVEL 5

CAMERA NUMBER	TYPE	LENS	RESOLUTION
C5-01	1	VARIFOCAL	5MP
C5-02	1	360 MULTI-IMAGER	4 X 5MP
C5-03	1	VARIFOCAL	5MP
C5-04	1	360 MULTI-IMAGER	4 X 5MP
C5-05	1	360 MULTI-IMAGER	4 X 5MP
C5-06	1	360 MULTI-IMAGER	4 X 5MP
C5-07	1	VARIFOCAL	5MP
C5-08	1	360 MULTI-IMAGER	4 X 5MP
C5-09	1	VARIFOCAL	5MP

FOR REFERENCE ONLY

Issue Date: 01/12/2024

Revisions

NUMBER	DESCRIPTION	DATE

UNLESS A PROFESSIONAL SEAL WITH SIGNATURE AND DATE IS AFFIXED, THIS DOCUMENT IS PRELIMINARY AND IS NOT INTENDED FOR CONSTRUCTION, RECORDING PURPOSES OR IMPLEMENTATION

STATE OF LOUISIANA
VINCE M. PE4
License No. 39726
PROFESSIONAL ENGINEER
11/12/2024

Key Plan:



TECHNOLOGY OVERALL PLAN - LEVEL 5

T205

CONSTRUCTION DOCUMENTS

1 LEVEL 5 - TECHNOLOGY OVERALL PLAN
1/8" = 1'-0"

PRINT DATE/TIME: 1/11/2024 11:51:36 AM