

FOR REFERENCE ONLY

GENERAL NOTES:

1. THE MODULAR DATA OUTLETS (OUTLETS INTEGRATED INTO CASEWORK) WHICH CONSIST OF THE PATCH CABLES THAT ARE TO BE WIRED TO THE CEILING DATA OUTLETS ARE CAPTURED ON THE CASEWORK ENLARGED PLANS LOCATED ON SHEET T411.

2. COMPLETE A X-RAY OR GPR SCAN BEFORE CORING THE EXISTING FLOOR. TYPICAL OF ALL POKE-THRU DEVICE LOCATIONS.

3. LOCATIONS OF FLOOR BOXES AND FLOOR PENETRATIONS SHALL NOT BE MEASURED FROM THIS PLAN. THE INSTALLER SHALL REQUEST PRECISE LOCATIONS FROM THE ARCHITECT.

KEYED NOTES:

1. DATA DEDICATED FOR REFRIGERATOR/FREEZER.

2. REFER TO SHEET T411 FOR MORE INFORMATION ON DATA REQUIREMENTS FOR LAB CASEWORK. TYPICAL OF ALL.

3. DATA OUTLET MOUNTED TO BOTTOM GANG OF AV BACKBOX. REFER TO 'ROUGH-IN FOR CREDEZZA RACK' DETAIL FOR MORE INFORMATION.

4. POWER POLE FOR DATA AND ELECTRICAL OUTLETS. REFER TO ELECTRICAL DRAWINGS AND SPECIFICATION FOR MORE INFORMATION.

5. TWO (2) 2" CONDUITS FROM POKE-THRU DEVICE TO ACCESSIBLE CEILING.

6. DATA DEDICATED FOR STERILIZER.

7. THE DISPLAYS IN THIS SECTION ARE 48" DIAGONAL. COORDINATE WITH DISPLAY INSTALLER FOR THE EXACT HEIGHT OF ALL OUTLETS INCLUDING PIPERS BEHIND THE DISPLAY PRIOR TO INSTALLATION. THE DISPLAYS AND BRACKETS ARE OWNER FURNISHED AND INSTALLED. THE AVAILABLE WALL SPACE BETWEEN THE DISPLAY BRACKETS VARIES DEPENDING ON THE MODEL USED AND THE PURPOSE OF THIS COORDINATION IS TO ENSURE THE OUTLETS ARE INSTALLED IN LOCATIONS THAT WILL NOT BE BLOCKED BY THE DISPLAY BRACKET.

8. PROVIDE 1" CONDUIT BETWEEN DATA OUTLETS IN SAME COLUMN OF DISPLAYS AND THEN TO ACCESSIBLE CEILING SPACE.

9. POWER OUTLET. REFER TO ELECTRICAL DRAWINGS FOR MORE INFORMATION.

2 LARGE CONFERENCE ROOM SECTION
3/4" = 1'-0"

1 LEVEL 5 - TECHNOLOGY - SECTOR B2
1/4" = 1'-0"

