



**KEYED NOTES**

1. PROVIDE AND INSTALL 8H X 4W X 3/4" PLYWOOD COVERING ALL WALLS OF THE TELECOMMUNICATIONS ROOM. INSTALL AT 4" TO 8" AFF.
2. PROVIDE TELECOMMUNICATIONS GROUND BAR.
3. PROVIDE 12" TUBULAR RUNWAY, INSTALLED AT 7'-6" AFF.
4. PROVIDE VERTICLE WIRE MANAGER.
5. PROVIDE ORTONICS MONTY 40 20 RACK. SHALL HAVE A MINIMUM CLEARANCE OF 3'-0" IN FRONT AND BACK OF RACK. REFER TO SPECIFICATION SECTION 27100.
6. PROVIDE FLOOR MOUNTED EQUIPMENT CABINET SHALL HAVE A MINIMUM CLEARANCE OF 3'-0" IN FRONT AND BACK OF RACK. REFER TO SPECIFICATION SECTION 27100.
7. PROVIDE ACCESS CONTROL PANELS WITH POWER SUPPLIES.
8. ROUTE TUBULAR RUNWAY OVER PARALLEL DATA RACKS AND CABINETS. PROVIDE WATER FALL BRACKETS TO SUPPORT CABLING ROUTED INTO WIRE MANAGEMENT UNITS.
9. COORDINATE BALLAST DRIVER AND LUMINAIRE LOCATIONS WITH TELECOMMUNICATIONS TUBULAR RUNWAY, DATA RACKS AND CABINETS PRIOR TO INSTALLATION.
10. PROVIDE END PANELS.
11. CONDUITS TURNING UP FROM UNDERGROUND. REFER TO FLOOR PLANS FOR CONDUIT ROUTE.
12. PROVIDE 18" VERTICAL TUBULAR RUNWAY AT CONDUIT STUDS FIRE RATED ASSEMBLIES THROUGH WALL FLOOR TO SUPPORT CABLING TO HORIZONTAL RUNWAY.
13. 2 X 1" (INTERIOR DIMENSIONS) SPACE DEDICATED FOR 2 HR FIRE RATED CHASE FOR PS DAS (BDA).
14. PROVIDE TWO (2) 4" CONDUIT SLEEVES TO IT ROOM BELOW.
15. PROVIDE 12" VERTICAL LADDER CABLE TRAY TO SUPPORT CABLING TO TRAY ABOVE.
16. TWO (2) 4" CONDUITS FROM MDF ROOM BELOW.

Issue Date: 01/12/2024

**Revisions**

NUMBER	DESCRIPTION	DATE
--------	-------------	------

