



GENERAL NOTES
1. VERTICAL WIRE MANAGERS ARE NOT SHOWN IN RACK ELEVATIONS FOR SIMPLICITY OF VIEW. SEE ENLARGED TELECOM ROOM PLANS AND SPECIFICATIONS SECTION 271000 FOR MORE INFORMATION.
2. DATA SHALL BE TERMINATED IN PATCH PANELS STARTING IN RACK 1. ONCE EIGHT PATCH PANELS ARE TERMINATED AT RACK 1, DATA SHALL TERMINATE IN RACK 3. ONCE RACK 1 AND 3 ARE AT FULL CAPACITY (8 PATCH PANELS EACH), RACK 2 SHALL BE USED.

Issue Date: 01/12/2024

Revisions

NUMBER	DESCRIPTION	DATE
--------	-------------	------

UNLESS A PROFESSIONAL SEAL WITH SIGNATURE AND DATE IS AFFIXED, THIS DOCUMENT IS PRELIMINARY AND IS NOT INTENDED FOR CONSTRUCTION, RECORDING PURPOSES OR IMPLEMENTATION

